



ALERT205

ALERT2 Transmitter



Table of contents

1. Introduction	1
2. Connect to the ALERT205	2
3. Configuration	3
3.1 Station parameters	3
3.2 Add sensors	4
3.3 Communications options	7
4. Dashboard and data monitoring/retrieval	10
4.1 Dashboard	10
4.2 Monitor	10
5. Set up user accounts	11
6. Diagnostics	12
7. More information	14

1. Introduction

The ALERT205 is an ALERT2 transmitter with several communications and package options that allow it to fit the needs of your application. Package options are canister, enclosure, and backplate—offering a variety of compatible installation methods. In addition, the reliable ALERT205 can measure nearly any sensor on the market and provide accurate, defensible data necessary for making critical, time-sensitive decisions.

To configure and deploy the ALERT205, use the easy-to-use, mobile-friendly, browser-based interface that is hosted by the transmitter. View the data in real time on the interface **Dashboard** and view, graph, and collect historical data from the **Monitor Data** page. View the interface using a computer or mobile device web browser using USB, Wi-Fi, or cellular, which eliminates the need for computer-based software.

NOTE:

The use of cellular or Wi-Fi requires optional hardware that must be specified when ordering.




FIGURE 1-1. ALERT205 packaged on a backplate, in a canister, and in an enclosure

2. Connect to the ALERT205



Watch the video: [ALERT205 Part 1, Introduction](#).


1. For the initial configuration, connect the ALERT205 to a computer USB port using the provided cable. The ALERT205 can also connect remotely to a computer by using cellular or Wi-Fi.

NOTE:

When connecting to the ALERT205 with a USB cable for the first time, the computer may ask if the computer should be discoverable by other computers on the network. Select **No** to continue.

TIP:

To use the ALERT205 system remotely (over a cellular or Wi-Fi connection), set up an account with **Administrator** privileges (see [Set up user accounts](#) (p. 11)).

2. Open a web browser and type **192.168.66.1** or [linktodevice.com](#) if using a USB connection. Type **192.168.67.1** if using a remote connection.
3. Once connected to the system with a web browser, navigate to the **Configuration** page to configure [Station parameters](#) (p. 3), [Add sensors](#) (p. 4), and set up [Communications options](#) (p. 7). To view the help in context for each parameter, click .


3. Configuration



Watch the video: [ALERT205 Part 2, Configuration.](#)

3.1 Station parameters

The **Station Parameters** apply to the whole station, not to a specific measurement or communications device.



1. Click **Configuration**.
2. Type a descriptive ALERT205 **Station Name**.
3. Type a **Station Source Address**. Every station in the ALERT2 network must have a unique source address.
4. Type a **Self Report Interval** (in seconds). The station will report to the home station at this interval to indicate that the station is functioning during sunny conditions. Click the **i** icon for a list of common intervals.
5. Type a **PakBus Address**. Every station in the ALERT2 network must have a unique PakBus address (1 to 3999).

3.2 Add sensors





FIGURE 3-1. Precipitation and water level sensors connected to an ALERT205 canister

To customize the system to read sensors, follow these steps:

1. Click **+ Add Measurement** to see a list of available sensors.



2. Add analog sensors and up to ten SDI-12 sensors including **Temperature & Humidity**, **Barometric Pressure**, **Precipitation**, **Soil Moisture**, **Solar Radiation**, **Water Level**, **Wind Speed & Direction**, and **Meteorological**. Available internal measurements include **Battery Voltage**, **Logger Temperature**, **GPS**, and **Enclosure Humidity** (canister package option only).


NOTE:

A warning will appear if two sensors have the same SDI-12 address. See step 3 for information about changing SDI-12 addresses.


3. After selecting a sensor, it will appear in the list with various parameters to configure the sensor for different applications. Click on the sensor name to expand its available settings.
 - a. Some parameters apply to the sensor in general such as the **SDI-12 address** (for SDI-12 sensors) and **Dashboard Label**. The **Dashboard Label** name must be descriptive enough that you can distinguish the sensor from other sensors of the same type on the dashboard.


NOTE:

Each sensor must have a unique SDI-12 address.

- b. Each sensor has one or more outputs such as **Temperature**, **Humidity**, **Stage**, **Pressure**, and **Voltage**.
4. View the wiring diagram for the sensor by clicking .

- Click **+ Enable Optional Output** to see the available optional outputs. This button only is displayed if optional outputs are available for the sensor. Click **Disable** on the right side of an output panel header to disable that option.



- For each optional output option, click the **Reporting** tab to set up the conditions that will trigger an event transmission.
 - Type the **Sensor ID**, which is used to identify this measurement in the ALERT2 transmissions. Each measurement value must have a unique **Sensor ID**. Click the  icon for the recommended ID numbers.
 - Type the **Change to Trigger Transmission** value. When the difference between the current measurement and previous measurement is greater than or equal to the **Change to Trigger Transmission** value, an event transmission is triggered.
 - Enable **ALERT2 via AL200** to generate an AL200 report when the trigger condition is met.
 - Enable **LoggerNet Call-Back via CELL2XX** for an optional output to initiate **LoggerNet** call-back when the trigger condition is met.
- Remove a sensor from the running configuration by clicking the trash can on the right side of the sensor heading.
- To reorder the sensors, drag them up or down in the list. This determines the order the system will measure the sensors. Also, if measuring multiple sensors of the same type (for example, **Water Level, Wind**), it determines the order those sensors are displayed on the **Dashboard**.

9. After adding and configuring all sensors, click [Apply to Station](#), then configure the communications options according to the following section.

3.3 Communications options

Communications hardware options are specified at order time. Configure the AL200 to communicate with the communications devices in your ALERT2 network. Other available devices are CELL2XX, Wi-Fi Access Point, and RF407.





FIGURE 3-2. Antenna connectors on the ALERT205 canister

To add communications devices and to customize the system communications hardware, follow these steps:

1. Click the [Communications](#) tab.
2. Click [+ Add Communications](#) to see a list of available devices.

3. Select the devices used in your system. After selecting a communications device, it will appear in the list with the parameters used to customize the device for your application.



4. Configure each communications device:

- a. **AL200 (standard hardware)**

This device is added by default to the system configuration. The AL200 is an ALERT2 encoder and modulator that transmits on an ALERT2 network. It can also achieve clock synchronization by using GPS.

Specify the **Frame Length**, **Slot Length**, **Offset** and other settings.

For more information on the AL200 settings, click the **i** icons for help.

- b. **CELL2XX (hardware option)**

Select the CELL2XX if your system has a CELL200-series modem. The CELL2XX can use **LoggerNet** (**LoggerNet** call-back) or other TCP communications such as a web browser to view the **Dashboard** or other pages.

Specify the **APN** and other cellular settings. If **LoggerNet** call-back is desired, click the **LoggerNet Call-back** tab and specify the **LoggerNet Call-Back IP Address** and other settings.

For more information on the CELL2XX settings, click the **i** icons for help.

c. **Wi-Fi Access Point (hardware option)**

If the system is Wi-Fi capable, select the **Wi-Fi Access Point** to allow another Wi-Fi enabled device, such as a smart-phone, to access the **Dashboard**.


Specify the **Network Name**, **Password**, and other Wi-Fi settings.




For more information on the **Wi-Fi Access Point** settings, click the  icons for help.

d. **RF407 (hardware option)**

Select **RF407** if your system has an RF407 radio. This enables the system to communicate with and read values from a Campbell Scientific data logger configured with an RF407. The RF407 is used in conjunction with the sensor **CSI Datalogger** that is under the **Wireless** category. For each **CSI Datalogger** sensor, add an RF407 and configure its settings to match those radio network.

Specify the **Network ID** and **Hop Sequence**.

For more information on the RF407 settings, click the  icons for help.

5. After adding and configuring communications options, click  to save the communications configuration to the station. Click  to keep a copy of the configuration. It can then be loaded to this or another station by clicking .

4. Dashboard and data monitoring/retrieval



Watch the video: [ALERT205 Part 3, Dashboard](#).

4.1 Dashboard

After configuring the measurements and communications, visit the ALERT205 **Dashboard** to verify their settings. The **Dashboard** displays current station status, internal measurements, and the current value for each configured measurement. The **Dashboard** also supports tasks such as triggering a test transmission, entering manual stage values, and adjusting precipitation accumulations.

The screenshot shows the ALERT205 Dashboard interface. At the top, there is a navigation bar with 'Dashboard' highlighted, along with 'Configuration', 'Monitor Data', and 'Diagnostics'. The main content area is divided into several sections:

- Station Health & Status:** A table showing station information.

Station Status	
Current Station Time	04/15/2020 09:31:25.002
Station Name	ALERT205
Time to Next Measurement	24
Time to Next S01	36
Time to Next Scheduled TX	756
System Status	Waiting for measurements
Trigger Test TX	<input type="button" value="Trigger"/>
- Internal Measurements:** A table showing internal sensor data.

Internal Measurements	
Battery Voltage	13.256 V
Logger Temperature	72.636 °F
GPS	3
- Water Level:** A section for water level data with input fields for Stage, Stage Manual, and Distance.


Water Level (C5475A)	
Stage	NAN m
Stage Manual	<input type="text" value="0.0"/> m
Distance	NAN m
- Meteorological:** A table showing meteorological data.

Meteorological (ClimaVUE 50)	
Precipitation	0 mm
Wind Speed	0.33 m/s
Wind Direction	97°
Air Temperature	71.34 °F
Barometric Pressure	25.49 inHg
Humidity Sensor Temp	72.68 °F
Tilt x Orientation	-19.2°
Tilt y Orientation	-7.3°

4.2 Monitor

1. Select **Monitor Data** to display real-time and historical data and save the data on a computer.
2. Select the values to display from the **Table List**.
3. Click the **Record** tab to display the real-time values for each field in the table.

- Click the **Table** tab to display a table of historical data. Type the number of **Records** to display, select the fields to plot, then click **Apply**. Use the scroll bars to move through the data to see all records. The table updates as new records are received.
- Click the **Graph** tab to display the data as a graph. Type the number of **Records** to display, select the fields to plot, then click **Apply**.



- To download data or table to a computer, click **Save**, select the file format, and apply filters. The file is saved to the C:/Downloads directory on your computer.

5. Set up user accounts

Set up user accounts to control who can remotely access the system. To remotely configure the system, set up a user account with **Administrator permission level**.

To manage user accounts, click **User Accounts** on the **Configuration** page to access the **User Account Setup** dialog. The computer must be connected over USB or logged in under a previously created account with administrator access. The following table explains the permission levels.

Permission level	Access
None	Disable an account without deleting it
Read Only	Permission to view the system values
Administrator	Permission to view the system values, to edit the system configuration, and to create and edit accounts

NOTE:

Creating an account with the user name **anonymous**, without a password, will allow the specified access to anyone that connects to the system without having to enter a user name. A default **anonymous** account exists with read-only access. This allows anyone to see the **Dashboard** and the **Monitor Data** pages without having to enter a user name.

NOTE:

The **anonymous** account without password must exist to properly access the system using the Apple Safari browser.

6. Diagnostics



Watch the video: [ALERT205 Part 4, Diagnostics](#).

The **Diagnostic** tab provides tools for displaying current status information, updating the ALERT205 operating system, and accessing watch modes used for troubleshooting or entering SDI-12 commands.

Status information

1. Click **Diagnostics**.
2. Click **Status**. The current status of parameters such as the operating system version or lithium battery voltage are displayed.

Updating the operating system

1. Go to www.campbellsci.com/downloads/al205b and click **Download Now**.
2. Click **Save File** then click **OK**. This will download the file on your computer, typically in the C:/Downloads folder.
3. Connect to the ALERT205 either directly with a USB cable or remotely through a Wi-Fi connection.
4. Select **Diagnostics > Updates > Update from file**.
5. Navigate to the folder containing the file. Select the file and click **Open**.
6. Follow the onscreen prompts to finish downloading the new operating system to the ALERT205.


Communications watch modes

1. Click **Diagnostics**
2. Click **Watch**
3. Use the drop-down menu to select a watch mode option and click **Start** to begin watching the selected mode.
 - a. **SDI-12 Watch** option displays SDI-12 commands and data sent between the ALERT205 and SDI-12 sensors. It is used for troubleshooting communications with SDI-12 sensors.
 - b. **RS-232 (AL200) Watch** option shows communications between the ALERT205 and AL200 modem. This is useful for troubleshooting the AL200 modem.

The screenshot shows the Campbell Scientific ALERT205 Diagnostics interface. The top navigation bar includes 'Dashboard', 'Configuration', 'Monitor Data', and 'Diagnostics' (highlighted with a red box). Below the navigation bar, the 'Diagnostics' section is active, with sub-tabs for 'Status', 'Updates', and 'Watch' (highlighted with a red box). The 'Communications Watch' section features a dropdown menu set to 'RS-232 (AL200) Watch' (highlighted with a red box) and two buttons: 'Start' (highlighted with a red box and a mouse cursor) and 'Stop'. Below the buttons, a log window displays the following text:

```
Watch started . . .
14:51:49.14 T 31 52 37 21 1R7!
14:51:49.71 R 31 28 30 28 30 2E 30 30 30 2B 30 2B 30 2B 30 2E 1+0+0.000+0+0+0.
14:51:49.71 R 31 34 28 31 30 32 2E 33 28 30 2E 31 35 28 32 33 14+102.3+0.15+23
14:51:49.71 R 2E 38 28 31 2E 31 31 28 38 36 2E 34 37 28 30 2E .8+1.11+86.47+0.
14:51:49.71 R 33 37 39 28 32 34 2E 37 28 31 2E 38 20 34 2E 35 379+24.7+1.8-4.5
14:51:49.84 T 30 40 21 0H!
14:51:49.94 T 30 40 21 0H!
14:51:50.03 T 30 40 21 0H!
14:51:50.14 T 30 40 21 0H!
14:51:50.23 T 30 40 21 0H!
14:51:50.33 T 30 40 21 0H!
14:51:50.44 T 30 40 21 0H!
14:51:50.53 T 30 40 21 0H!
14:51:50.62 T 30 40 21 0H!
Stopped.
```

- c. SDI-12 Talk-Through Watch option opens a terminal for sending SDI-12 commands to an attached SDI-12 sensor.



- i. Type the sensor address, choose the command from the drop-down menu, and click **Send**. The results of the command will appear in the terminal window.
 - ii. Alternatively, type the SDI-12 command directly into the terminal window. Refer to the sensor manual for a list of SDI-12 commands available for the sensor.
4. Click **Stop** to end and switch to a different diagnostic mode or return to the **Dashboard** or **Monitor Data** screens.

7. More information

For more information, contact [Campbell Scientific](#) .



Global Sales & Support Network

A worldwide network to help meet your needs



Campbell Scientific regional offices

Australia

Location: Garbutt, QLD Australia
Phone: 61.7.4401.7700
Email: info@campbellsci.com.au
Website: www.campbellsci.com.au

Brazil

Location: São Paulo, SP Brazil
Phone: 11.3732.3399
Email: vendas@campbellsci.com.br
Website: www.campbellsci.com.br

Canada

Location: Edmonton, AB Canada
Phone: 780.454.2505
Email: dataloggers@campbellsci.ca
Website: www.campbellsci.ca

China

Location: Beijing, P. R. China
Phone: 86.10.6561.0080
Email: info@campbellsci.com.cn
Website: www.campbellsci.com.cn

Costa Rica

Location: San Pedro, Costa Rica
Phone: 506.2280.1564
Email: info@campbellsci.cc
Website: www.campbellsci.cc

France

Location: Vincennes, France
Phone: 0033.0.1.56.45.15.20
Email: info@campbellsci.fr
Website: www.campbellsci.fr

Germany

Location: Bremen, Germany
Phone: 49.0.421.460974.0
Email: info@campbellsci.de
Website: www.campbellsci.de

India

Location: New Delhi, DL India
Phone: 91.11.46500481.482
Email: info@campbellsci.in
Website: www.campbellsci.in

South Africa

Location: Stellenbosch, South Africa
Phone: 27.21.8809960
Email: sales@campbellsci.co.za
Website: www.campbellsci.co.za

Spain

Location: Barcelona, Spain
Phone: 34.93.2323938
Email: info@campbellsci.es
Website: www.campbellsci.es

Thailand

Location: Bangkok, Thailand
Phone: 66.2.719.3399
Email: info@campbellsci.asia
Website: www.campbellsci.asia

UK

Location: Shepshed, Loughborough, UK
Phone: 44.0.1509.601141
Email: sales@campbellsci.co.uk
Website: www.campbellsci.co.uk

USA

Location: Logan, UT USA
Phone: 435.227.9120
Email: info@campbellsci.com
Website: www.campbellsci.com